ESCUELA NACIONAL
DE LA JUDICATURA
REPÚBLICA DOMINICANA
PODER JUDICIAL

Circular 1

Respuestas de inquietudes del proceso Núm. ENJ-CS-2021-266. Compra de 1 tarjeta para aire acondicionado ubicado en la recepción interna de la Escuela Nacional de la Judicatura.

Fecha de publicación 28 de abril 2021

Pregunta Núm. 1

¿Qué marca es el aire acondicionado?

Respuesta:

Ver imagen anexa

Pregunta Núm. 2

Si es posible foto de la placa del aire, que dice toda la información de este.

Respuesta:

Ver imagen anexa

Pregunta Núm. 3

Es importante mencionar que no se cambia una tarjeta sin buscar porque se dañó, porque si no se arregla la causa puede volver a afectarse la nueva tarjeta.

Respuesta:

La causa es el error que presenta la imagen anexa.


E1
CIAC


CIAC
Air conditioning
CARRIER INTERAMERICA CORPORATION
SPLIT TYPE AIR CONDITIONER
HEAT PUMP OUTDOOR UNIT
Model
CM43AX024--H3H1H
Voltage/Phase
208/230V/1
Frequency
60Hz
Compressor
RLA
18.0A
LRA
-
Fan Motor
1/6HP
1.5A
Design Pressure(High)
550PSIG
3.8MPa
Design Pressure(Low)
240PSIG
1.7MPa
Max Fuse Size
40A
Min. Circuit Ampacity
24.0A
Refrigerant(R410A)
4.9LBS
2.2kg
Weight
152.1LBS
69.0kg
Manufacture Date
08/2016
SERIAL NO.
8647960000786
Indoor Model
CC43AX024-E3H1H
CK43AX024-C3H1H
CF43AX024-M3H1H
Intertek
CERTIFIED TO
CSA STD. C22.2
MADE IN CHINA